

# LACKAWANNA CITY SCHOOL DISTRICT

## Water Samples Greater than 15 ppb

### McKinley Administrative Building

Location	Fountain near Rm. 206	Fountain near Rm. 209
Results	26.1	16.0
Remediation	Flushed water lines	Flushed water lines
Results	5.63	6.82
Back in Use	1/19/2017	1/19/2017

### Martin Road Elementary

Location	Kitchen Sink
Results	16.6
Remediation	Replaced Faucet
Results	ND
Back in Use	1/11/2017

### Lackawanna High School

Location	Kitchen Sink
Results	92.7
Remediation	Replaced Faucet
Results	ND
Back in Use	1/11/2017

### Lackawanna Middle School

Location	Boys Bathroom Sink
Results	51.9
Remediation	Replaced Faucet
Results	ND
Back in Use	1/11/2017

### Truman Elementary

Location	Room 5	Room 6	Room 7	Room 8	Room 9	Room 10	Room 11
Results	25.2	38.5	31.3	17.1	30.2	23.1	35.4
Remediation	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines
Results	3.48	3.15	20.2	6.41	8.52	2.23	2.79
Back in Use	1/11/2017	1/11/2017	No	1/11/2017	1/11/2017	1/11/2017	1/11/2017
Remediation			turned water off				

Location	Room 13	Room 15	Room 18	Room 19	Room 20	Room 21	Room 22
Results	85.0	42.3	29	33.4	25.5	51.00	29.8
Remediation	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines
Results	17.8	14.2	5.26	25.6	24.2	16.3	3.51
Back in Use	No	1/11/2017	1/11/2017	No	No	No	1/11/2017
Remediation	turned water off			turned water off	turned water off	turned water off	

Location	Room 24	Room 25	Room 26	Room 27	Room 28	Room 29
Results	16	18.7	58.6	23.6	18.7	21.9
Remediation	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines	Flushed water lines
Results	3.3	7.63	10.8	5.76	2.24	1.95
Back in Use	1/11/2017	1/11/2017	1/11/2017	1/11/2017	1/11/2017	1/11/2017